



# Attestation of Conformity

## Screened Category 6 ISO/IEC, EN & TIA/EIA Connecting Hardware

### Telebox Identification P/N TA8668SX

Category 6, Screened, Keystone Jack  
Electrical Transmission Performance

**Telebox Industries Corp.**  
**4F, No. 306, Tatung Road, Sec. 1**  
**Hsichih-Taipei 221, Taiwan, R.O.C.**

#### *Attestation of Conformity No. 105469*

*This Screened ISO/IEC, EN & TIA/EIA Connecting Hardware having board identification "001-8670 C6 1F00 N35 L09-0" has been tested by 3P Third Party Testing and complies with the Category 6 transmission requirements of 2nd edition ISO/IEC Generic Cabling Standard 11801, CENELEC Generic Cabling Standard EN 50173-1, ANSI/TIA/EIA Generic Cabling Standard 568-B.2-1 and draft IEC Connecting Hardware Standard 60603-7-5. The mated pair requirements are passed using the complete specified de-embedded range of RJ 45 plugs. The Attestation of Conformity is valid for the actually tested connecting hardware samples and no verification of the running production is performed.*

Hoersholm, 19 May 2005

*Ole Lambertsen*

Ole Lambertsen  
Test Responsible

Hoersholm, 19 May 2005

*Paul Villien*

Poul Villien  
Coordinating Manager