



Compliance Statement

Screened Category 6 ISO/IEC, EN & TIA/EIA Connecting Hardware

Telebox Identification P/N LP2461Sx

Category 6, Screened, Patch Panel
Electrical Transmission Performance

**Telebox Industries Corp.
4F, No. 306, Tatung Road, Sec. 1
Hsichih-Taipei 221, Taiwan, R.O.C.**

Compliance Statement No. 110487

This Screened RJ 45 Patch Panel with board identification "Cat.6 001-0871 C6 1F00" has been tested by 3P Third Party Testing and complies with the Category 6 transmission requirements of 2nd edition ISO/IEC Generic Cabling Standard 11801, amendment 2 to 2nd edition ISO/IEC Generic Cabling Standard 11801 (draft 25 N 1645), CENELEC Generic Cabling Standard EN 50173-1:2007, ANSI/TIA/EIA Generic Cabling Standard 568-B.2-1, 2nd edition IEC Connecting Hardware Standard 60603-7-5 (draft 48B/2009/CDV) and IEC 60512-26-100. The qualification activity includes factory and assembly line inspection and passing of mated pair requirement using the complete specified Category 6 de-embedded NEXT range of RJ 45 plugs. The Compliance Statement may be suspended or withdrawn if the modular jack fails to pass a Maintenance Testing performed at 12 month intervals.

Hoersholm, 27th January 2010

Ole Lambertsen

Ole Lambertsen
Test Responsible

Hoersholm, 27th January 2010

Poul Villien

Poul Villien
Coordinating Manager